



सत्यमेव जयते

Government of West Bengal

Office of the RWS Assistant Engineer, RWS Burdwan Sub-Division, P.H.E.Dte.
P.H.E. Complex, Nababhat, Purba Bardhaman.

Memo No.~35..... /DL

Dated, Purba Bardhaman, the, 12.06.2026

To,
Sri Chaitanya Techno School
Renaissance Township, Nawabhat
Purba Bardhaman-713102

Sub:- Submission of results of Chemical & Bacteriological analysis of water sample
Sri Chaitanya Techno School, Renaissance Township, Nawabhat, Purba
Bardhaman-713102

Sir/Madam,

As desired by you vide your letter I am submitting herewith the result of chemical & Bacteriological analysis of water sample of above subject in original. . In this connection it may be stated herewith that the approved charges for the testing of water samples amounting to Rs.2,210.00 (Rupees Two Thousand Two Hundred Ten only) received by the Office of the Executive Engineer, Burdwan Division, PHE Dte. vide GRN No.192026270085894268, dt. 08.06.2026.
Thanking you,

Yours faithfully,

Enclos:- Result Sheet.

Assistant Engineer
R.W.S Burdwan Sub-Division
P.H.E.Dte.

Memo No.~ /DL

Dated, Purba Bardhaman, the,2026

Copy forwarded for information to :-

1. The Executive Engineer, Burdwan Division, P.H.E.Dte.
Enclosed:- Result sheet.

Assistant Engineer
R.W.S Burdwan Sub-Division
P.H.E.Dte.

BURDWAN DISTRICT WATER TESTING LABORATORY

UNDER BURDWAN DIVISION , PUBLIC HEALTH ENGINEERING DIRECTORATE

P.H.E COMPLEX NABABHAT, DISTRICT- PURBA BARDHAMAN, PINCODE: 713104

Gmail: bdndistlab@gmail.com

Date of Issue: 12.06.2026

Sample Details					
Name of Customer:-		Sri Chaitanya Techno School		Type of Source:-	RO Plant Water
				Sample Receive on	08.06.2026
Sample Id:-		11638		Test Completed on	09.06.2026
Sample Package Condition:-				Nature of Sample	Drinking Water
a. Quantity of Sample - 1000ml (Non Acidic)				Sample Collected & Provide By:	Sampling Assistant of Burdwan District Laboratory
b. Quantity of Sample - 250ml (Acidic)					
c. Quantity of Sample - 200ml (For Bacteriological Test)				Sample Location:-	Renaissance Township, Nawabhat Purba Bardhaman-713102
TEST REPORT					
Sl.	Test Parameters	Units	Requirements IS 10500:2012		Results
			Acceptable Limit	Permissible Limit	
1	pH at 25°C	-	6.5-8.5	No Relaxation	6.50
2	Total Dissolved Solids(TDS)	mg/l, Max	500	2000	27
3	Turbidity	NTU, Max	1	5	0.38
4	Total Hardness(as CaCO ₃)	mg/l, Max	200	600	20
5	Iron as Fe	mg/l, Max	1.0	No Relaxation	0.01
6	Manganese as Mn	mg/l, Max	0.1	0.3	0
7	Total Coliform	CFU/100 ml	Must not be detectable in 100 ml sample	Must not be detectable in 100 ml sample	0
8	E. Coli	CFU/100 ml	Must not be detectable in 100 ml sample	Must not be detectable in 100 ml sample	0

Chaitanya
12/6/26 skmd
12/6/26

Chemist /Bacteriologist
Burdwan District Laboratory
P.H.E.Dte

Chaitanya
Assistant Engineer
RWS Burdwan Sub-Division
P.H.E.Dte.

Note:

1. The contents of the report shall not be reproduced either in full or in part without prior written consent of the issuing authority.
2. The results relate only to the items tested.

End of the Report

Printed by Payal Das

পশ্চিমবঙ্গ সরকার
মুখ্য স্বাস্থ্য আধিকারিকের করণ
পূর্ব বর্ধমান



Government of West Bengal

Office of the Chief Medical Officer of Health
Purba Bardhaman

Memo No: Dy. CMOH-II/ 364

Date: 31-07-2026

TO WHOM IT MAY BE CONCERNED

It is certified that an inspection team headed by Dy.Chief Medical Officer of Health-II, of the Office of Chief Medical Officer of Health, Purba Bardhaman, inspected the Sri Chaitanya Techno School, Renaissance Township, Purba Bardhaman on 31.7.2026 and found that Sri Chaitanya Techno School has safe drinking water facilities for the students and staff members are maintaining the hygiene and sanitation condition in the school campus building as per norms prescribed by the State Government.

The above certificate is valid for a period of one year from the date of issuing this certificate.


31.07.26

Dy. Chief Medical Officer of Health-II
Purba Bardhaman

To
Sri Chaitanya Techno School
Renaissance Township, Nabwabhat
Purba Bardhaman, 7131021